

إعلان طرح عطاء

١. تعلن القيادة العامة للقوات المسلحة الأردنية/ قيادة سلاح الجو الملكي عن طرح العطاء رقم س ج/ت ف/٢٥/٢٠٢٥/٤٠ وهو عبارة عن شراء وتركيب خزانات وقود جديدة عدد (٢) إثنان
٢. على الراغبين بالاشتراك مراجعة قسم المشتريات بقيادة سلاح الجو الملكي خلال ساعات الدوام الرسمي ليومي الثلاثاء والخميس من كل إسبوع ابتداءً من يوم الثلاثاء الموافق ٢٠٢٥/٨/١٩ ولغاية يوم الثلاثاء الموافق ٢٠٢٥/٩/٩ لإستلام نسخة كشف المواصفات مقابل (٥٠) خمسون دينار فقط غير مستردة مصطحبين معهم رخصة مهن سارية المفعول وسجل تجاري.
٣. آخر موعد لبيع المناقصات يوم الثلاثاء الموافق ٢٠٢٥/٩/٩ وخلال ساعات الدوام الرسمي.
٤. تعاد المناقصات بالظرف المختوم خلال ساعات الدوام الرسمي ليس بعد يوم الخميس الموافق ٢٠٢٥/٩/١١ ولن تقبل أية مناقصة ترد بعد هذا الوقت.
٥. للإطلاع على كشف المواصفات المطلوبة للعطاء يرجى زيارة الموقع الإلكتروني الرسمي لقيادة سلاح الجو الملكي (WWW.RJAF.MIL.JO).

كشف المواصفات الفنية

#	Technical Specifications		Qty
1.	Fuel Tank Specification	Horizontal Steel Tank Above Ground	2
		54000L Exact Usable Capacity	2
		Fuel Tank Thickness 6mm "one layer"	2
2.	Fuel Tank Essential Accessories	External Fuel Tank Stairs	2
		Fill Hole, Supply Hole, Drain Hole, Maintenance Hole, Ventilation Hole, Return Line Hole, Measurement Hole	For each tank
		Exterior Protective Coating "paint"	2
		"Saddle support Structure" Ground Rules	3 for each tank
		Internal Bridges (Baffle) to Support Fuel Tank Structure	---
		Tank monitoring system (electronic or sight glass) optional	2
3.	1ph, 2hp Fuel Pump Explosion Proof Bypass Pressure Regulator Pump	Supply, Installation & Commissioning Pump	2
		All materials needed to connect Pump to nearest power supply	10m
		Install pumps control panel (IP65)	1
		Note: Provide Us Datasheet for quoted Pump	---
4.	Dispensing System (Pipelines & valves Connections)	Connect New Fuel Tank to existing networks pipes include all fittings, valves Etc. Note: pipe diameter & class must compatible with quoted pump.	30m
		supply line from Bozzer to tank with coupling "filling line "	20m
		Drain line	20m
		Note: Clarify Pipe Class	---
5.	Safety Features	Bypass Valve	2
		Thermal & pressure Relief valve	2
		Non – sparking Materials "Brass & stainless "	--
		One point Grounding Fuel Tank "nearly distance between fuel tank and grounding point 20m "	20m cable
6.	Regulatory Compliance & Standards	Third party inspection by an accredited Company	---